

File Original with
Department of Ecology

Second Copy - Owner's Copy

Third Copy - Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

33-1E-24P

Notice of Intent

W 159676

UNIQUE WELL ID # AGR 533

Water Right Permit No

(1) OWNER. Name EASTGATE KOORN #2 Address 1923 HASTIE LK RD, OAK HARBOR WA(2) LOCATION OF WELL: County ISLAND SE 1/4 SW 1/4 Sec 24 T 33 N R 1E WM(2a) STREET ADDRESS OF WELL: (or nearest address) TRISHA LANE, OAK HARBOR WA, 98277
TAX PARCEL NO. R 133 24-(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal
☐ Irrigation ☐ Test Well ☐ Other
☐ DeWater(4) TYPE OF WORK: Owner's number of well (if more than one) 2
☒ New Well Method ☐ Dug ☐ Bored
☐ Deepened ☒ Cable ☐ Driven
☐ Reconditioned ☐ Rotary ☐ Jetted
☐ Decommission(5) DIMENSIONS: Diameter of well 6 inches
Drilled 137 feet Depth of completed well 137 ft

(6) CONSTRUCTION DETAILS

Casing Installed:

☒ Welded 6 " Diam from 0 ft to 127 ft
☐ Liner installed " Diam from " ft to " ft
☐ Threaded " Diam from " ft to " ft

Perforations:

☐ Yes ☒ No

Type of perforator used

Size of perforations " in by " in
perforations from " ft to " ft

Screens:

☒ Yes ☐ No ☒ K-Pac Location 126Manufacturer's Name ALLOYS INC.Type STAINLESS (2) Model No 304Diam 6 Slot Size 10 from 127 ft to 132 ftDiam 6 Slot Size 10 from 132 ft to 137 ftGravel/Filter packed: ☐ Yes ☒ No ☐ Size of gravel/sand

Material placed from " ft to " ft

Surface seal: ☒ Yes ☐ No To what depth? 20 ftMaterial used in seal BENTONITEDid any strata contain unusable water? ☐ Yes ☒ No

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name NONE

Type " HP

(8) WATER LEVELS: Land-surface elevation above mean sea level 156 ftStatic level 82 ft below top of well Date 1-2003

Artesian pressure lbs per square inch Date

Artesian water is controlled by (Cap, valve, etc)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield " gal/min with " ft drawdown after " hrs

Yield " gal/min with " ft drawdown after " hrs

Yield " gal/min with " ft drawdown after " hrs

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

Date of test

Bailer test 10 gal/min with 12 ft drawdown after 3 hrs

Airtest " gal/min with " ft drawdown after " hrs

Artesian flow " g p m Date

Temperature of water " Was a chemical analysis made? ☐ Yes ☒ No(10) WELL LOG or DECOMMISSIONING PROCEDURE DESCRIPTION
Formation Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered

MATERIAL	FROM	TO
GRAVELY	0	12
SANDY CLAY	12	88
CLAY	88	110
SANDY CLAY	110	121
WATER SAND	121	137

RECEIVED

JAN 15 2003

DEPT OF ECOLOGY

RECEIVED

JAN 07 2003

DEPT OF ECOLOGY

Work Started DEC 29, 2003 Completed JAN 4, 2003

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Type or Print Name GARY BOONSTRA License No 038
(Licensed Driller/Engineer)

Trainee Name " License No "

Drilling Company WHIDBEY DRILLERS(Signed) Pennie John License No 129
(Licensed Driller/Engineer)Address OAK HARBOR WA 98277Contractor's
Registration No WHID289 MM Date JAN 4 2003

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (360) 407-6600. The TDD number is (360) 407-6006.